

Status Report - MHR-T (Russian Federation)

Downloaded on: Oct 02, 2026 8:28 AM CET
Published Date : Oct 17, 2024 2:46 PM CET

1. Overview

- ☐ In Operation
- ☐ Under Construction
- ☐ Described in

Link to PRIS --

☒ **New Concept**

Number of Units --

Year --

Reference Plant

Name of Site --

Link to PRIS --

Net Power Output (MWe) 205.5

Gross Power Output (MWe) --

1.1 Introduction

The MHR-T reactor/hydrogen production complex makes use of the basic GT-MHR reactor unit design as the basis for a multi-module plant for hydrogen production. The hydrogen production through the steam methane reforming process or high-temperature solid oxide electrochemical process is performed by coupling the plant with the modular helium reactor(s). The use of modular helium reactor units makes the system flexible and allows the possibility to use various power unit schemes: with gas-turbine cycle (GTMHR design), steam-turbine cycle and with the circuit supplying high-temperature heat to industrial applications (this design). The modular high temperature gas-cooled reactor unit possess salient safety features with passive decay heat removal providing high level of safety even in case of total loss of primary coolant.

The most perspective technologies for Russia are hydrogen production through the steam methane reforming process or high-temperature solid oxide electro-chemical process coupled with a modular helium reactor called MHR-T. The chemical-technological sector with steam methane reforming is considered as an option for short-term perspective.




Figure 1. MHR-T design concept.

1.2 Development Milestones

2001	Pre-conceptual proposal
2005	Conceptual design completed
2007	Elaboration of technical requirements
2017	Feasibility study of plant application for large-scale hydrogen production
2020	Development of basic design solutions for chemical-technological part of the facility

1.3 Design organization or vendor company

1.4 Links to designer/vendor website

1.5 Design Description

The MHR-T complex includes the chemical-technological sector (hydrogen production sector) and the infrastructure supporting its operation. The chemical-technological sector includes hydrogen production process lines, as well as systems and facilities supporting their operation.

The following processes are considered as the basic processes for the chemical-technological sector: (i) steam methane reforming; and (ii) high-temperature solid oxide electrochemical process of hydrogen

production from water. Heat shall be transferred directly from primary coolant to chemical-technological sector medium in a high-temperature heat exchanger. The key component of chemical-technological sector medium circulating through the high-temperature heat exchanger is water steam. The high-temperature electrolysis option allows the consideration of two- and three-circuit plant configurations. The technical concept is based on:

- Modular helium-cooled reactors with typical high level of inherent safety;
- Fuel cycle based on uranium dioxide in the form of multi-layer coated particles, high burnup and burial of fuel blocks unloaded from the reactor without any additional processing;
- Electromagnetic bearings operating almost without friction and applied in various technical areas;
- Highly efficient high-temperature compact heat exchangers, strong vessels made of heat resistant steel.

The thermal energy generated in the reactor is converted to chemical energy in a thermal conversion unit (TCU) where, in the MHR-T option with methane reforming, the initial steam-gas mixture is converted to hydrogen-enriched converted gas (mixture of water steam, CO, H₂, CO₂, and CH₄) in the course of a thermochemical reaction.

1.6 Licensing Application Support Documents

1.7 Reactor Unit in PRIS

2. Category Fields

Table 1: ARIS Category Fields

ARIS Category	Value	Units of Examples
Current/Intended Purpose	Commercial – Electric/Non-Electric	e.g. Commercial – Electric/Non-electric, Prototype/FOAK, Demonstration, Experimental
Main Intended Application (once commercial)	Baseload, Non-electric (hydrogen production and high temperature process heat application.)	e.g. Baseload, Dispatchable, Off-grid/Remote, Mobile/Propulsion, Non-electric (specify)
Reference Location	Inland	e.g. On Coast, Inland, Below-Ground, Floating-Fixed, Marine-Mobile, Submerged-Fixed (Other-specify)
Reference Site Design (reactor units per site)	Multiple Units (4 units)	e.g. Single Unit, Dual Unit, Multiple Unit (# units)
Core Coolant	He	H ₂ O, D ₂ O, He, CO ₂ , Na, Pb, PbBi, Molten Salts, (Other-specify)

Reactor Core Size (1 core)	30 MWth <= Thermal power < 1000 MWth	e.g. Thermal Power < 30 MWth, 30 MWth ≤ Thermal power < 1000 MWth, 1000 MWth ≤ Thermal power ≤ 3000 MWth, Thermal power > 3000 MWth
Reactor Type	GCR	e.g. PWR, BWR, HWR, SCWR, GCR, GFR, SFR, LFR, MSR, ADS
Reactor Size	SMR	e.g. PWR, SMR
Neutron Moderator	Graphite	e.g. H ₂ O, D ₂ O, He, CO ₂ , Na, Pb, PbBi, Molten Salts, (Other-specify)
NSSS Layout		e.g. Loop-type (# loops), Direct-cycle, Semi-integral, Integral, Pool-type
Primary Circulation	Forced	e.g. Forced (# pumps), Natural
Thermodynamic Cycle		e.g. Rankine, Brayton, Combined-Cycle (direct/indirect)
Secondary Side Fluid		e.g. H ₂ O, He, CO ₂ , Na, Pb, PbBi, Molten Salts, (Other-specify)
Fuel Form	Coated Sphere	e.g. Fuel Assembly/Bundle, Coated Sphere, Plate, Prismatic, Contained Liquid, Liquid Fuel/Coolant
Fuel Lattice Shape	Hexagonal	e.g. Square, Hexagonal, Triangular, Cylindrical, Spherical, Other, n/a
Rods/Pins per Fuel Assembly/Bundle		e.g. #, n/a
Fuel Material Type	Oxide	e.g. Oxide, Nitride, Carbide, Metal, Molten Salt, (Other-specify)
Design Status	Conceptual Design	e.g. Conceptual, Detailed, Final (with secure suppliers)
Licensing Status		e.g. DCR, GDR, PSAR, FSAR, Design Licensed (in Country), Under Construction (# units), In Operation (# units)
Neutron Spectrum	Thermal	e.g. Fast, Thermal

3. Parameter Fields

Table 2: ARIS Parameter Fields

ARIS Parameter	Value	Units of Examples
Plant Infrastructure		
Design Life	60	Years
Lifetime Capacity Factor		%, defined as Lifetime MWe- yrs delivered / (MWe capacity * Design Life), incl. outages
Major Planned Outages		# days every # months (specify purpose, including refuelling)
Operation / Maintenance Human Resources		# Staff in Operation / Maintenance Crew during Normal Operation
Reference Site Design		n Units/Modules
Capacity to Electric Grid	205.5	MWe (net to grid)
Non-electric Capacity		e.g. MW(th) heat at x °C, m3/day desalinated water, kg/day hydrogen, etc.
In-House Plant Consumption		MWe
Plant Footprint		m2 (rectangular building envelope)
Site Footprint		m2 (fenced area)
Emergency Planning Zone		km (radius)
Releases during Normal Operation		TBq/yr (Noble Gases / Tritium Gas / Liquids)
Load Following Range and Speed		x – 100%, % per minute
Seismic Design (SSE)		g (Safe-Shutdown Earthquake)
NSSS Operating Pressure (primary side)		MPa(abs), i.e. MPa(g)+0.1, at core outlet
NSSS Operating Pressure (secondary side)		MPa(abs), i.e. MPa(g)+0.1, at secondary side outlet
Primary Coolant Inventory (incl. pressurizer)		kg
Nominal Coolant Flow Rate (primary)		kg/s

Nominal Coolant Flow Rate (secondary)		kg/s
Core Inlet Coolant Temperature		°C
Core Outlet Coolant Temperature		°C
Available Temperature as Process Heat Source		°C
NSSS Largest Component		e.g. RPV (empty), SG, Core Module (empty/fuelled), etc.
- NSSS Largest Component Length		mm
- NSSS Largest Component Diameter		mm
- NSSS Largest Component Thickness		mm
- NSSS Largest Component Weight		tonne
Reactor Vessel Material		e.g. SS304, SS316, SA508, 800H, Hastelloy N
Steam Generator Design		e.g. Vertical/Horizontal, U- Tube/ Straight/Helical, cross/counter flow
Secondary Coolant Inventory		kg
Pressurizer Design		e.g. separate vessel, integral, steam or gas pressurised, etc.
Pressurizer Volume		m ³ / m ³ (total / liquid)
Containment Type		Dry (single/double), Dry/Wet Well, Inerted, etc.
Containment Volume		m ³
Spent Fuel Pool Capacity and Total Volume		Years of full-power operation / m ³
Non Electric Application		-
Core Delta Temperature		°C
Fuel/Core		
Single Core Thermal Power		MW(th)
Refuelling Cycle		months or “continuous”

Fuel Material		e.g. UO ₂ , MOX, UF ₄ , UCO
Enrichment (avg./max.)		%
Average Neutron Energy		eV
Fuel Cladding Material		e.g. Zr-4, SS, TRISO, E-110, none
Number of Fuel "Units"		Specify as Assembly, Bundle, Plate, Sphere, or n/a
Weight of one Fuel Unit		kg
Total Fissile Loading (initial)		kg fissile material (specify isotopic and chemical composition)
% of fuel outside core during normal operation		Applicable to online refuelling and molten salt reactors
Fraction of fresh-fuel fissile material used up at discharge		%
Core Discharge Burnup		MWd/kgHM (heavy metal, eg U, Pu, Th)
Pin Burnup (max.)		MWd/kgHM
Breeding/Conversion Ratio		Fraction of fissile material bred in-situ over one fuel cycle or at equilibrium core
Reprocessing		e.g. None, Batch, Continuous (FP polishing/actinide removal), etc.
Main Reactivity Control		e.g. Rods, Boron Solution, Fuel Load, Temperature, Flow Rate, Reflectors
Solid Burnable Absorber		e.g. Gd ₂ O ₃
Core Volume (active)		m ³ (used to calculate power density)
Fast Neutron Flux at Core Pressure Boundary		n/(cm ² *s)
Max. Fast Neutron Flux		n/(cm ² *s)
Core Control Rod Absorber		-
Core Soluble Neutron Absorber		-
Safety Systems		

Number of Safety Trains	Active / Passive	% capacity of each train to fulfil safety function
- reactor shutdown	Active/Passive	- / - / -
- core injection	Active/Passive	- / - / -
- decay heat removal	Active/Passive	- / - / -
- containment isolation and cooling	Active/Passive	- / - / -
- emergency AC supply (e.g. diesels)	Active/Passive	- / - / -
DC Power Capacity (e.g. batteries)		Hours
Events in which Immediate Operator Action is required		e.g. any internal/external initiating events, none
Limiting (shortest) Subsequent Operator Action Time		Hours (that are assumed when following EOPs)
Severe Accident Core Provisions		e.g. no core melt, IMMR, Core Catcher, Core Dump Tank, MCCI
Core Damage Frequency (CDF)		x/reactor-year (based on reference site and location)
Severe Accident Containment Provisions		e.g., H2 ignitors, PARs, filtered venting etc.
Large Release Frequency (LRF)		x/reactor-year (based on reference site and location)
Overall Build Project Costs Estimate or Range (excluding Licensing, based on the Reference Design Site and Location)		
Construction Time (nth of a kind)		Months from first concrete to criticality
Design, Project Mgmt. and Procurement Effort		Person-years (PY) [DP&P]
Construction and Commissioning Effort		PY [C&C]
Material and Equipment Overnight Capital Cost		Million US\$(2015) [M&E], if built in USA
Cost Breakdown	%[C&C]/%[M&E]	
- Site Development before first concrete		(e.g. 25/10) (30/40)
- Nuclear Island (NSSS)		

- Conventional Island (Turbine and Cooling)		(20/25) (20/10) (5/15) (-----) (to add up to 100/100)
- Balance of Plant (BOP)		
- Commissioning and First Fuel Loading		
Factory / On-Site split in [C&C] effort		%/% of total [C&C] effort in PY (e.g., 60/40)
Nuclear System		
System Steam Flow Rate		kg/s
System Steam Pressure		MPa
System Steam Temperature		°C
System Feedwater Flow Rate		kg/s
System Feedwater Temperature		°C
Reactor Core		
Active Core Height		m
Equivalent Core Diameter		m
Average Linear Heat Rate		kW/m
Average Fuel Power Density		kW/kgU
Average Core Power Density		MW/m ³
Outer Diameter Of Fuel Rods		mm

4. Plant Layout, Site Environment and Grid Integration

SUMMARY FOR BOOKLET

NPP module are arranged in isolated premises of the underground containment of the NPP main building. The chemical-technological sector equipment is arranged outside the containment of the NPP main building. The MHR-T energy-technological complex is designed for a specific site on the basis of design solutions selected with account of climatic conditions typical of central Russia and special external impacts such as seismicity, aircraft crash, air shock wave. The interfaces between the four-module NPP and the chemical-technological sector must be designed to except faults that could cause failure of more than one MHR-T module. The main reactor equipment is arranged in a vertical vessel located in a separate cavity parallel to the power conversion unit and high-temperature heat exchanger vessels.




Figure 2. Plant layout arrangement

4.1 Site Requirements during Construction

4.2 Site Considerations during Operation

4.3 Grid Integration

5. Technical NSSS/Power Conversion System Design

SUMMARY FOR BOOKLET

Power Conversion System

A power conversion unit is integrated in a single vessel and includes a vertical turbomachine, highly efficient plate heat exchanger, and coolers. A high-temperature heat exchanger (IHX) for the MHR-T option with methane steam reforming is an integral part of the thermal conversion unit and is partitioned as a three-stage heat exchanger. Arrangement of the heat exchanger sections along the primary coolant flow is parallel, and downstream of the coolant in the chemical-technological sector (CTS) is sequential. Each section is designed as a separate heat exchanger consisting of several modules.

The material of the heat exchange surface of the module is a heat-resistant alloy. The turbomachine includes a generator and turbo-compressor mounted on a single shaft on electromagnetic suspension. The gas turbine cycle of power conversion with the helium turbomachine, heat exchanger and intercooler provide a thermal efficiency of 48%.




Figure 2. Power conversion unit




Figure 3. High temperature heat exchanger section

Reactor Core and Fuel Characteristics

Coated particle fuel is used. The fuel kernel (U oxide) is coated by a first porous layer of pyrocarbon, followed by a dense layer of pyrocarbon, a silicon carbide layer and an outer dense layer of pyrocarbon. Thousands of coated particles and graphite matrix material are made into a fuel compact with thousands of compacts inserted into the fuel channels of the Hexagonal Prism graphite blocks or fuel assemblies.

The coated particles will contain almost all fission products with temperatures up to 1600oC. About 1 billion fuel particles of the same type were manufactured and tested in Russia. The standard fuel cycle is to utilize low enriched uranium (LEU) in a once through mode. The MHR-T show good proliferation resistance characteristics. It produces less total plutonium and ²³⁹Pu (materials of proliferation concern) per unit of energy produced. The fuel form presents formidable challenges to diversion of materials for weapons production, as either fresh or as spent fuel.

Reactor Coolant System

Working media in circulation circuits are helium of the primary circuit and steam-gas mixture (SGM) in the CTS. The peculiarity of heat exchangers for the production of hydrogen by methane reforming process is the transfer of heat from high temperature helium of the primary circuit to the chemically aggressive medium of hydrogen production circuit.

Reactivity Control

Two independent reactivity control systems based on different operation principles are used to execute reactor emergency shutdown and maintenance in a sub-critical state. These systems are: 1) Electromechanical reactivity control system based on control rods moving in the reactor core channels and in the inner and outer reflectors; 2) Reserve shutdown system based on spherical absorbing elements that fill-in channels in the fuel assembly stack over the whole height of a fuel assembly. Control rods with boron carbide absorbing elements located in the reflector used during normal operation and hot shutdown, and rods located in the core used for scram.

Reactor Pressure Vessel and Internals

Reactor Pressure Vessel made of chromium-molybdenum steel is 29 m height with outer diameter (across flanges) 8.2 m. Prerequisites and conditions excluding brittle fracturing of the reactor vessel include keeping the fast neutron fluence on the reactor vessel and the vessel temperature below the allowable limits. In-vessel structures, namely, prismatic fuel blocks, reflectors, and core support structure are made of graphite, and metallic structures are made of chromium-nickel alloy. Service life of the reactor vessel and internals is 60 years.

Instrumentation and Control Systems

The MHR-T NPP control and support safety systems (CSS) are intended to actuate the equipment, mechanisms and valves, localizing and support safety systems in the pre-accidental conditions and in accidents; to monitor their operation; and to generate control commands for the equipment of normal operation systems used in safety provision algorithms. The CSS are based on the principles of redundancy, physical and functional separation, and safe failure.

5.1 Primary Circuit

5.2 Reactor Core and Fuel

5.3 Fuel Handling

5.4 Reactor Protection

5.5 Secondary Side

5.6 Containment/Confinement

5.7 Electrical, I&C and Human Interface

5.8 Unique Technical Design Features (if any)

6. Technology Readiness

SUMMARY FOR BOOKLET

Design and Licensing Status

Feasibility study of plant application for large-scale hydrogen production completed. Currently, safety issues are the major area of R&D with the emphasis on mutual influence of nuclear and hydrogen production components of the facility.

6.1 Deployed Reactors

6.2 Reactors under Licensing Review

6.3 Reactors in the Design Stage

7. Safety Concepts

SUMMARY FOR BOOKLET

The safety features of the MHR-T reactor are the same as for the GT-MHR. Safety objectives for the MHR-T are achieved, first of all, by relying on the inherent safety features incorporated in the plant design. The design features are as follows:

- Using helium as the coolant. During operation, helium is not affected by phase transformations. It does not dissociate and has good heat transfer properties. Helium is chemically inert. It does not react with fuel, moderator and structural materials. There are no helium reactivity effects;
- Core and reflector structural material is high-density reactor graphite with substantial heat capacity and heat conductivity and sufficient mechanical strength that maintain core configuration integrity;
- Nuclear fuel in the form of coated fuel particles with multilayer ceramic coatings, which retain integrity and effectively contain fission products under high fuel burnup and high temperatures;
- The temperature and power reactivity coefficients are negative that provides the reactor safety in any design and accident conditions.

Safety is ensured by application of passive principles of system actuation. The decay and accumulated heat is removed from the core through reactor vessel to reactor cavity cooling system and then to atmosphere by natural physical processes of heat conductivity, radiation, convection. In case of LOCA with failures of all active circulation systems and power sources, operation limits of the fuel are not exceeded.

Engineered Safety System Approach and Configuration

Special considerations are devoted to external impacts from the hydrogen production sector. In addition to the inherent (self-protection) features of the reactor, the MHR-T plant incorporates safety systems based on the following principles: 1) Simplicity of both system operation algorithm and design; 2) Usage of natural processes for safety system operation under accident conditions; 3) Redundancy, physical separation and independence of system channels; 4) Stability to the internal and external impacts and malfunctions caused by accident conditions; 5) Continuous or periodical diagnostics of system conditions; 6) Conservative approach used in the design, applied to the list of initiating events,

to accident scenarios, and for the selection of the definitive parameters and design margins.

Reactor Cooling Philosophy

High heat storage capacity of the reactor core and high acceptable temperatures of the fuel and graphite allow passive shutdown cooling of the reactor in accidents, including LOCA (heat removal from the reactor vessel by radiation, conduction and convection), while maintaining the fuel and core temperatures within the allowable limits. The MHR-T follows the GT-MHR design principles with no dedicated active safety systems (active systems of normal operation are used for safety purposes) and with emergency heat removal also possible by the reactor cavity cooling system (see GT-MHR for more details).

Containment Function

The approach is the same as for the GT-MHR with passive localization of radioactivity provided by the containment as well as external loads (see GT-MHR for more details).

Plant Safety and Operational Performances

All safety systems are designed with two channels. Fulfilment of the regulatory requirements on safety, proven by a compliance with both deterministic and probabilistic criteria, is secured by an exclusion of the active elements in a channel or by applying the required redundancy of such active elements inside a channel, as well as via the use of the normal operation systems to prevent design basis accidents.

7.1 Safety Philosophy and Implementation

7.2 Transient/Accident Behaviour

8. Fuel and Fuel Cycle

SUMMARY FOR BOOKLET

Fuel Cycle Approach

The MHR-T fuel cycle approach is a once through mode without reprocessing. Appropriately shielded containers are provided to protect the personnel against radiation impacts during dismantling of the reactor unit components at fuel reloading. These measures are also applied at spent fuel management.

Waste Management and Disposal Plan

Facilities for long-term storage of spent nuclear fuel (SNF) and solid/solidified radioactive waste (RW) are included in the complex of an MHR-T commercial 4-unit NPP. The capacity of the designed SNF storage is determined from the condition of capability to store fuel unloaded from the NPP for 10 years. The estimated total volume of the SNF reception and storage compartments is around 150 000 m³. The capacity of solid/solidified RW storage facility is designed to provide storage of waste generated

during the 10-year period of NPP operation. After 10 years of storage at the NPP site, SNF and RW are to be removed for final underground disposal.

8.1 Fuel Cycle Options

8.2 Resource Use Optimization

8.3 Unique Fuel/Fuel Cycle Design Features

9. Safeguard & Physical Security

SUMMARY FOR BOOKLET

9.1 Safeguards

9.2 Security

9.3 Unique Safeguards and/or Security Features

10. Project Delivery & Economics

SUMMARY FOR BOOKLET

10.1 Project Preparation and Negotiation

10.2 Construction and Commissioning

10.3 Operation and Maintenance