

# Status Report - VBER-300 (Russian Federation)

Downloaded on: Oct 02, 2026 8:28 AM CET  
Published Date : Oct 18, 2024 9:53 AM CET

## 1. Overview

- ☐ In Operation
- ☐ Under Construction
- ☐ Described in

Link to PRIS --

☒ **New Concept**

Number of Units --

Year --

### Reference Plant

Name of Site --

Link to PRIS --

Net Power Output (MWe) 325

Gross Power Output (MWe) --

### 1.1 Introduction

The VBER-300 is a multipurpose medium-sized power reactor with a rated electric power of 325 MW intended for land-based nuclear power plants (NPPs), nuclear cogeneration plants, and transportable floating nuclear power plants (FNPPs). The VBER-300 design is evolution of modular marine propulsion reactors. An increase in thermal power causes an increase in mass and overall dimensions; however, the reactor basic design is similar to that of marine propulsion reactors. The VBER-300 design was developed based on the lessons learned from the design, safety and operating experience for VVER reactors. VBER-300 adopts proven nuclear ship building technologies and operating experience that in turn contribute to enhancement of operational safety and reduction in production costs. VBER-300 can be configured as a multi-module plant on request of the customer. VBER-300 design features are availability for both land-based and transportable FNPPs, a variety of cogeneration options, maximally compact design, improved plant efficiency, and protection against external impacts. A reduction in construction time is achieved due to the compact design of the reactor system.

The VBER-300 nuclear plants are intended to supply thermal and electric power to remote areas where centralized power is unavailable, and to substitute capacities of available cogeneration plants on fossil fuels. The design is also proposed to be used as a power source for seawater desalination

complexes. The VBER-300 nuclear plant has two reactor units that operate in the steam-condensing mode and can generate 600 MW(e) to satisfy power demands of a city with a population of 300 000. According to the OKBM's data, when VBER-300 has cogeneration capabilities, the total electric output will reduce to 200 MW(e) providing 460 Gcal/hr for process heat applications.




Figure 1. VBER-300 design concept

## 1.2 Development Milestones

|           |                                                                                                                                                                                                                                                       |
|-----------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2001      | Design activities to develop VBER reactors started                                                                                                                                                                                                    |
| 2022      | Technical and commercial proposal for the two-unit VBER NPP                                                                                                                                                                                           |
| 2004      | Preliminary design 1 approved by the Scientific and Technical Board and State Nuclear Supervision Body (GosAtomNadzor)                                                                                                                                |
| 2006      | JSC “Kazakhstan-Russian company “Atomic stations” was established to promote the VBER-300 design.                                                                                                                                                     |
| 2007-2009 | Technical Assignment for the NPP design and final designs of the reactor plant, automated process control system, and heat-generating plant; feasibility, economy, and investment studies of the VBER-300 RP NPP for the Mangistau Region, Kazakhstan |
| 2007-2008 | Development of the 100–600 MW VBER plant                                                                                                                                                                                                              |
| 2008-2011 | R&D for the VBER-460/600 NPP design                                                                                                                                                                                                                   |
| 2011-2012 | Development of the VBER-600/4 NPP based on the heat exchange loop of the increased capacity                                                                                                                                                           |
| 2012-2015 | Technical and economic optimization of the VBER-600/4 plant                                                                                                                                                                                           |

### 1.3 Design organization or vendor company

### 1.4 Links to designer/vendor website

### 1.5 Design Description

VBER-300 design using ship-based modular configuration enhances the safety philosophy through proven marine modular technologies. The reactor design has no pipelines in the primary circulation circuit. The reactor unit incorporates the reactor and four steam generators – MCPs two-vessel units. The compact reactor system comprises the steam generating system in a limited space of the reactor compartment, and has enhanced reliability and long refuelling cycle. VBER-300 can also be configured as a transportable FNPP and can be arranged to operate individually or as multi-module plant, increasing the power output by means of scaling up the equipment and with the same reactor system configuration.

### 1.6 Licensing Application Support Documents

### 1.7 Reactor Unit in PRIS

## 2. Category Fields

Table 1: ARIS Category Fields

| ARIS Category                                  | Value                                                                     | Units of Examples                                                                                                                   |
|------------------------------------------------|---------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------|
| Current/Intended Purpose                       | Commercial – Electric/Non-Electric                                        | e.g. Commercial – Electric/Non-electric, Prototype/FOAK, Demonstration, Experimental                                                |
| Main Intended Application (once commercial)    | Baseload, Non-electric (district heating, sea water desalination), Marine | e.g. Baseload, Dispatchable, Off-grid/Remote, Mobile/Propulsion, Non-electric (specify)                                             |
| Reference Location                             | Inland, Floating-Fixed                                                    | e.g. On Coast, Inland, Below-Ground, Floating-Fixed, Marine-Mobile, Submerged-Fixed (Other-specify)                                 |
| Reference Site Design (reactor units per site) |                                                                           | e.g. Single Unit, Dual Unit, Multiple Unit (# units)                                                                                |
| Core Coolant                                   | H2O                                                                       | H2O, D2O, He, CO2, Na, Pb, PbBi, Molten Salts, (Other-specify)                                                                      |
| Reactor Core Size (1 core)                     | 30 MWth <= Thermal power < 1000 MWth                                      | e.g. Thermal Power < 30 MWth, 30 MWth ≤ Thermal power < 1000 MWth, 1000 MWth ≤ Thermal power ≤ 3000 MWth, Thermal power > 3000 MWth |

|                                    |                         |                                                                                                               |
|------------------------------------|-------------------------|---------------------------------------------------------------------------------------------------------------|
| Reactor Type                       | PWR                     | e.g. PWR, BWR, HWR, SCWR, GCR, GFR, SFR, LFR, MSR, ADS                                                        |
| Reactor Size                       | SMR                     | e.g. PWR, SMR                                                                                                 |
| Neutron Moderator                  | H2O                     | e.g. H2O, D2O, He, CO2, Na, Pb, PbBi, Molten Salts, (Other-specify)                                           |
| NSSS Layout                        | Integral                | e.g. Loop-type (# loops), Direct-cycle, Semi-integral, Integral, Pool-type                                    |
| Primary Circulation                | Forced                  | e.g. Forced (# pumps), Natural                                                                                |
| Thermodynamic Cycle                | Rankine                 | e.g. Rankine, Brayton, Combined-Cycle (direct/indirect)                                                       |
| Secondary Side Fluid               | H2O                     | e.g. H2O, He, CO2, Na, Pb, PbBi, Molten Salts, (Other-specify)                                                |
| Fuel Form                          | Fuel Assembly/Bundle    | e.g. Fuel Assembly/Bundle, Coated Sphere, Plate, Prismatic, Contained Liquid, Liquid Fuel/Coolant             |
| Fuel Lattice Shape                 | Hexagonal               | e.g. Square, Hexagonal, Triangular, Cylindrical, Spherical, Other, n/a                                        |
| Rods/Pins per Fuel Assembly/Bundle |                         | e.g. #, n/a                                                                                                   |
| Fuel Material Type                 | Oxide                   | e.g. Oxide, Nitride, Carbide, Metal, Molten Salt, (Other-specify)                                             |
| Design Status                      | Under Regulatory Review | e.g. Conceptual, Detailed, Final (with secure suppliers)                                                      |
| Licensing Status                   |                         | e.g. DCR, GDR, PSAR, FSAR, Design Licensed (in Country), Under Construction (# units), In Operation (# units) |
| Neutron Spectrum                   | Thermal                 | e.g. Fast, Thermal                                                                                            |

### 3. Parameter Fields

Table 2: ARIS Parameter Fields

| ARIS Parameter       | Value | Units of Examples |
|----------------------|-------|-------------------|
| Plant Infrastructure |       |                   |

|                                                  |      |                                                                                               |
|--------------------------------------------------|------|-----------------------------------------------------------------------------------------------|
| Design Life                                      | 60   | Years                                                                                         |
| Lifetime Capacity Factor                         |      | %, defined as Lifetime MWe-<br>yrs delivered / (MWe capacity<br>* Design Life), incl. outages |
| Major Planned Outages                            |      | # days every # months<br>(specify purpose, including<br>refuelling)                           |
| Operation / Maintenance<br>Human Resources       |      | # Staff in Operation /<br>Maintenance Crew during<br>Normal Operation                         |
| Reference Site Design                            |      | n Units/Modules                                                                               |
| Capacity to Electric Grid                        | 325  | MWe (net to grid)                                                                             |
| Non-electric Capacity                            |      | e.g. MW(th) heat at x °C,<br>m3/day desalinated water,<br>kg/day hydrogen, etc.               |
| In-House Plant Consumption                       |      | MWe                                                                                           |
| Plant Footprint                                  |      | m2 (rectangular building<br>envelope)                                                         |
| Site Footprint                                   |      | m2 (fenced area)                                                                              |
| Emergency Planning Zone                          |      | km (radius)                                                                                   |
| Releases during Normal<br>Operation              |      | TBq/yr (Noble Gases / Tritium<br>Gas / Liquids)                                               |
| Load Following Range and<br>Speed                |      | x – 100%, % per minute                                                                        |
| Seismic Design (SSE)                             | 0.25 | g (Safe-Shutdown<br>Earthquake)                                                               |
| NSSS Operating Pressure<br>(primary side)        | 16.3 | MPa(abs), i.e. MPa(g)+0.1, at<br>core outlet                                                  |
| NSSS Operating Pressure<br>(secondary side)      | 6.37 | MPa(abs), i.e. MPa(g)+0.1, at<br>secondary side outlet                                        |
| Primary Coolant Inventory<br>(incl. pressurizer) |      | kg                                                                                            |
| Nominal Coolant Flow Rate<br>(primary)           |      | kg/s                                                                                          |
| Nominal Coolant Flow Rate<br>(secondary)         |      | kg/s                                                                                          |
| Core Inlet Coolant<br>Temperature                | 292  | °C                                                                                            |

|                                              |                                          |                                                                        |
|----------------------------------------------|------------------------------------------|------------------------------------------------------------------------|
| Core Outlet Coolant Temperature              | 325                                      | °C                                                                     |
| Available Temperature as Process Heat Source |                                          | °C                                                                     |
| NSSS Largest Component                       | Reactor vessel                           | e.g. RPV (empty), SG, Core Module (empty/fuelled), etc.                |
| - NSSS Largest Component Length              | 9300                                     | mm                                                                     |
| - NSSS Largest Component Diameter            | 3900                                     | mm                                                                     |
| - NSSS Largest Component Thickness           |                                          | mm                                                                     |
| - NSSS Largest Component Weight              |                                          | tonne                                                                  |
| Reactor Vessel Material                      |                                          | e.g. SS304, SS316, SA508, 800H, Hastelloy N                            |
| Steam Generator Design                       |                                          | e.g. Vertical/Horizontal, U-Tube/ Straight/Helical, cross/counter flow |
| Secondary Coolant Inventory                  |                                          | kg                                                                     |
| Pressurizer Design                           |                                          | e.g. separate vessel, integral, steam or gas pressurised, etc.         |
| Pressurizer Volume                           |                                          | m <sup>3</sup> / m <sup>3</sup> (total / liquid)                       |
| Containment Type                             |                                          | Dry (single/double), Dry/Wet Well, Inerted, etc.                       |
| Containment Volume                           |                                          | m <sup>3</sup>                                                         |
| Spent Fuel Pool Capacity and Total Volume    |                                          | Years of full-power operation / m <sup>3</sup>                         |
| Non Electric Application                     | district heating, sea water desalination | -                                                                      |
| Core Delta Temperature                       | 36                                       | °C                                                                     |
| <b>Fuel/Core</b>                             |                                          |                                                                        |
| Single Core Thermal Power                    | 917                                      | MW(th)                                                                 |
| Refuelling Cycle                             | 72                                       | months or “continuous”                                                 |
| Fuel Material                                | UO <sub>2</sub>                          | e.g. UO <sub>2</sub> , MOX, UF <sub>4</sub> , UCO                      |
| Enrichment (avg./max.)                       | 4.95                                     | %                                                                      |
| Average Neutron Energy                       |                                          | eV                                                                     |

|                                                              |                                |                                                                                      |
|--------------------------------------------------------------|--------------------------------|--------------------------------------------------------------------------------------|
| Fuel Cladding Material                                       |                                | e.g. Zr-4, SS, TRISO, E-110, none                                                    |
| Number of Fuel "Units"                                       |                                | Specify as Assembly, Bundle, Plate, Sphere, or n/a                                   |
| Weight of one Fuel Unit                                      |                                | kg                                                                                   |
| Total Fissile Loading (initial)                              |                                | kg fissile material (specify isotopic and chemical composition)                      |
| % of fuel outside core during normal operation               |                                | Applicable to online refuelling and molten salt reactors                             |
| Fraction of fresh-fuel fissile material used up at discharge |                                | %                                                                                    |
| Core Discharge Burnup                                        | 50                             | MWd/kgHM (heavy metal, eg U, Pu, Th)                                                 |
| Pin Burnup (max.)                                            |                                | MWd/kgHM                                                                             |
| Breeding/Conversion Ratio                                    |                                | Fraction of fissile material bred in-situ over one fuel cycle or at equilibrium core |
| Reprocessing                                                 |                                | e.g. None, Batch, Continuous (FP polishing/actinide removal), etc.                   |
| Main Reactivity Control                                      | control rods and soluble boron | e.g. Rods, Boron Solution, Fuel Load, Temperature, Flow Rate, Reflectors             |
| Solid Burnable Absorber                                      |                                | e.g. Gd <sub>2</sub> O <sub>3</sub>                                                  |
| Core Volume (active)                                         |                                | m <sup>3</sup> (used to calculate power density)                                     |
| Fast Neutron Flux at Core Pressure Boundary                  |                                | n/(cm <sup>2</sup> *s)                                                               |
| Max. Fast Neutron Flux                                       |                                | n/(cm <sup>2</sup> *s)                                                               |
| Core Control Rod Absorber                                    |                                | -                                                                                    |
| Core Soluble Neutron Absorber                                |                                | -                                                                                    |
| <b>Safety Systems</b>                                        |                                |                                                                                      |
| Number of Safety Trains                                      | Active / Passive               | % capacity of each train to fulfil safety function                                   |
| - reactor shutdown                                           | Active/Passive                 | - / - / -                                                                            |
| - core injection                                             | Active/Passive                 | - / - / -                                                                            |

|                                                                                                                             |                |                                                                                                         |
|-----------------------------------------------------------------------------------------------------------------------------|----------------|---------------------------------------------------------------------------------------------------------|
| - decay heat removal                                                                                                        | Active/Passive | - / - / -                                                                                               |
| - containment isolation and cooling                                                                                         | Active/Passive | - / - / -                                                                                               |
| - emergency AC supply (e.g. diesels)                                                                                        | Active/Passive | - / - / -                                                                                               |
| DC Power Capacity (e.g. batteries)                                                                                          |                | Hours                                                                                                   |
| Events in which Immediate Operator Action is required                                                                       |                | e.g. any internal/external initiating events, none                                                      |
| Limiting (shortest) Subsequent Operator Action Time                                                                         |                | Hours (that are assumed when following EOPs)                                                            |
| Severe Accident Core Provisions                                                                                             |                | e.g. no core melt, IMMR, Core Catcher, Core Dump Tank, MCCI                                             |
| Core Damage Frequency (CDF)                                                                                                 |                | x/reactor-year (based on reference site and location)                                                   |
| Severe Accident Containment Provisions                                                                                      |                | e.g., H2 ignitors, PARs, filtered venting etc.                                                          |
| Large Release Frequency (LRF)                                                                                               |                | x/reactor-year (based on reference site and location)                                                   |
| <b>Overall Build Project Costs Estimate or Range (excluding Licensing, based on the Reference Design Site and Location)</b> |                |                                                                                                         |
| Construction Time (nth of a kind)                                                                                           |                | Months from first concrete to criticality                                                               |
| Design, Project Mgmt. and Procurement Effort                                                                                |                | Person-years (PY) [DP&P]                                                                                |
| Construction and Commissioning Effort                                                                                       |                | PY [C&C]                                                                                                |
| Material and Equipment Overnight Capital Cost                                                                               |                | Million US\$(2015) [M&E], if built in USA                                                               |
| Cost Breakdown                                                                                                              | %[C&C]/%[M&E]  |                                                                                                         |
| - Site Development before first concrete                                                                                    |                | (e.g. 25/10 )<br>( 30/40 )<br>( 20/25 )<br>( 20/10 )<br>( 5/15 )<br>( ----- )<br>(to add up to 100/100) |
| - Nuclear Island (NSSS)                                                                                                     |                |                                                                                                         |
| - Conventional Island (Turbine and Cooling)                                                                                 |                |                                                                                                         |
| - Balance of Plant (BOP)                                                                                                    |                |                                                                                                         |
| - Commissioning and First Fuel Loading                                                                                      |                |                                                                                                         |

|                                         |  |                                                |
|-----------------------------------------|--|------------------------------------------------|
| Factory / On-Site split in [C&C] effort |  | %/% of total [C&C] effort in PY (e.g., 60/40 ) |
| <b>Nuclear System</b>                   |  |                                                |
| System Steam Flow Rate                  |  | kg/s                                           |
| System Steam Pressure                   |  | MPa                                            |
| System Steam Temperature                |  | °C                                             |
| System Feedwater Flow Rate              |  | kg/s                                           |
| System Feedwater Temperature            |  | °C                                             |
| <b>Reactor Core</b>                     |  |                                                |
| Active Core Height                      |  | m                                              |
| Equivalent Core Diameter                |  | m                                              |
| Average Linear Heat Rate                |  | kW/m                                           |
| Average Fuel Power Density              |  | kW/kgU                                         |
| Average Core Power Density              |  | MW/m <sup>3</sup>                              |
| Outer Diameter Of Fuel Rods             |  | mm                                             |

## 4. Plant Layout, Site Environment and Grid Integration

### SUMMARY FOR BOOKLET

In the basic architecture of the land-based VBER-300 power unit, the reactor, including its servicing systems, spent fuel pool, and auxiliary equipment are arranged within a double containment resistant to aircraft crashes.




Figure 1. Plant layout

### Reactor Building

The inner steel shell is a leak-tight cylindrical enclosure 30 m in diameter that is covered with the semi-spherical dome 15 m in radius and that has an elliptical bottom. The height of the leak-tight enclosure is 47 m. The steel shell is designed for parameters of the maximum DBA with the excess pressure of 0.4 MPa and the temperature of 150°C. The outer protective enclosure is made of one-piece reinforced concrete without preliminary tensioning of the steel and consists of a cylindrical portion of the semi-spherical dome. Building structures of the outer protective enclosure are designed for external accidental exposures, including an aircraft crash and air shock wave.

### Balance of Plant

The VBER-300 design can be configured for land-based stationary applications wherein the reactor system – a nuclear island coupled to a turbine island and auxiliary buildings for spent fuel storage, water treatment, maintenance, and switchyard connections with configurations similar to conventional large LWRs – are housed in a relatively small area.

### Turbine Generator Building

Each VBER-300 reactor system can be thermally coupled with one or multiple turbine generator sets. A slightly superheated steam is supplied to the turbine in the secondary circuit with part of the steam taken off from the turbine and directed to the heat exchanger of a district heating circuit. It can operate as a NPP with a condensing turbine and as a nuclear cogeneration plant with a cogeneration turbine.

## 4.1 Site Requirements during Construction

## 4.2 Site Considerations during Operation

## 4.3 Grid Integration

# 5. Technical NSSS/Power Conversion System Design

## SUMMARY FOR BOOKLET

## **Nuclear Steam Supply System**

The separation heat exchangers are designed to extract heat energy from the nuclear heat source without mixing the fluids circulating within the nuclear plant with those employed in the process heat application. In the VBER-300 design, separation heat exchangers are thermally coupled indirectly via heat exchangers coupled with the secondary loop supporting the power conversion system. In this configuration, a stream of the steam generated via steam generators (for any of the 2, 3, and 4 SGs) and partially expanded in the turbines is extracted at an intermediate pressure for circulation within the separation heat exchangers.

### **Reactor Core**

The reactor core comprises 85 hexagonal fuel assemblies (FAs) which are placed in the reactor cavity in nodes of a regular triangular lattice with a space interval of 236 mm. Pelletized UO<sub>2</sub> fuel with an enrichment of up to 5% licensed and tested in VVER reactors is used. FA of unified design to increase the fuel efficiency is utilized. Each FA contains guide tubes that allow insertion/withdrawal of control rods. Reactor core also uses gadolinium fuel elements, which contain gadolinium in the UO<sub>2</sub> fuel pellet and has the same geometry as the regular fuel pellet.

### **Reactivity Control**

Sixty one control rods in combination with fuel elements mixed with burnable poison materials provide safe and reliable reactivity control during both normal and transient operations. Control rods are operated through high-performance electromechanical control rod drive mechanisms (CRDMs). The control rods elements are designed to maintain the core subcritical even if the most reactive assembly fails (i.e. stuck-rod/assembly event). To compensate for the fuel burnup reactivity margin, fuel rods with gadolinium burnable poison contained in uranium dioxide pellets are distributed across each FA with configurations similar to those used in VVER-1000 reactors. Boric acid is also dissolved and maintained at controlled concentrations within the primary coolant system to ensure optimum core power distribution.

### **Reactor Pressure Vessel and Internals**

The reactor pressure vessel (RPV) consists of the reactor core and internals with an overall height of 9.3 m and a diameter of 3.9 m. The VBER-300 design provides a special system of emergency vessel cooling to solve the problem of retaining the melt inside the reactor vessel in severe accidents. The core melt retention is facilitated by the low power density, relatively low level of residual heat, no penetrations in the reactor vessel bottom and smooth outer surfaces of the reactor vessel bottom creating more favourable conditions for steam evacuation under core cooling by boiling water.

### **Reactor Coolant System**

The VBER-300 primary cooling mechanism under normal operating conditions operates using forced circulation of coolant by the MCPs and using natural circulation in the shutdown condition. The reliability and operational safety of the MCPs are enhanced due to the usage of a proven technology and operating experience for the pumps in the area of marine propulsion. The MCPs are connected directly to the steam generators (SGs). All components of the primary loop are directly connected to the RPV, except for the pressurizer. The MCPs are centrifugal single-stage canned pumps with impellers.

## **Steam Generator**

The SGs are once-through coil modules with the secondary coolant flowing inside the tubes. The feedwater is pumped through an inlet in the SG head, circulates within the SG tubes and exits through the SG outlet as a superheated steam at the design pressure and temperature for expansion in the turbine generator units.

## **Pressurizer**

The VBER-300 has an external steam pressurizer that is conventional for loop PWRs. The water region in the pressurizer, where electric heaters are located, is connected with the SG hot section in one primary loop. The steam region of the pressurizer is connected with the cold section in this loop near the MCP pressure chamber, from which the underheated water is supplied to the pressurizer when valves are open in the injection line. The pressurizer head in the steam region has two safety valves that protect the primary circuit against overpressure in case of accidents with loss of decay heat removal.

### **5.1 Primary Circuit**

### **5.2 Reactor Core and Fuel**

### **5.3 Fuel Handling**

### **5.4 Reactor Protection**

### **5.5 Secondary Side**

### **5.6 Containment/Confinement**

### **5.7 Electrical, I&C and Human Interface**

### **5.8 Unique Technical Design Features (if any)**

## **6. Technology Readiness**

## **SUMMARY FOR BOOKLET**

### **Design and Licensing Status**

Development of the final design and design documentation for a VBER-300 nuclear station can begin immediately upon the request of a customer. It will take 36 months to develop documentation to the extent needed to obtain a license for VBER-300 NPP construction, including 18 months to develop the design.

### **Fuel Cycle Approach**

The VBER-300 design concept allows a flexible fuel cycle for the reactor core with standard VVER FAs. The fuel cycles are  $3 \times 2$  years and  $4 \times 1.5$  years. The number of FAs in the refuelling batch is either 15 or 30; maximal fuel burnup does not exceed 60 GWd/ton U for the cycle with 30 fresh FAs in the reloading batch and maximum initial uranium enrichment.

## 6.1 Deployed Reactors

## 6.2 Reactors under Licensing Review

## 6.3 Reactors in the Design Stage

# 7. Safety Concepts

## SUMMARY FOR BOOKLET

The VBER-300 safety systems are based on the defence-in-depth principle with redundancy relying on passively driven systems that enables the core to operate within safety margins under all anticipated accident scenarios for at least 24 hours. After this initial period, emergency back-up and diverse safety systems ensure continued core cooling for extended time. In addition, separation of the passive and active cooling channels prevents common failures of the emergency core cooling systems (ECCS).

### **Engineered Safety System Approach and Configuration**

The safety assurance and engineering solutions incorporated in the design focus on accident prevention measures, design simplification, inherent safety; passive safety systems and enhancement of safety against external events (including acts of terrorism); and mitigation of severe accident consequences. The RPV and connecting piping that usually form the primary pressure boundary represent an additional physical barrier. The leak-tight carbon steel containment and protective enclosure with filtration forms the ultimate barrier separating the reactor system from the environment. For all cogeneration applications, the separation of heat exchangers represents a physical barrier to prevent radioactive release.

### **Decay Heat Removal System**

The decay heat removal system (DHRS) consists of two passive heat exchangers and a process condenser. Passive safety features are intended to arrange recirculation in the core for the removal of decay heat in the course of scheduled maintenance, refuelling or under emergency conditions. Passive emergency shutdown cooling system operates using natural circulation of coolant in all heat transport circuits with stored water tanks, where water is evaporated and condensed back to liquid upon a contact with the cooler surfaces of the containment inner shell. Decay heat is also removed indirectly by the secondary circuit using the steam turbine condenser.

### **Emergency Core Cooling System**

The ECCS contains two stages accumulators with different flow-rate characteristics to ensure emergency core cooling for 24 hours, makeup pumps and a recirculation system. If electrical power is available during accidents, makeup pumps and an active recirculation system ensures emergency core cooling beyond the initial 24 hours. The VBER-300 emergency shutdown system consists of the CRDMs, two trains of liquid absorber injection, and two trains of boron control from the make-up system. Emergency residual heat removal system (RHRS) by means of passive cooling channels with water tanks and in-built heat exchangers, ensure reliable cooling up to 72 hours and longer. The system is actuated by passive means—hydraulically operated pneumatic valves. The emergency core cooling accumulators are part of the passive water injection system as injection is done using

compressed gas. Containment depressurization systems prevent containment damage and reduce radioactive release in design basis accidents (DBA) and beyond DBAs. A small and medium loss of coolant accidents (LOCA) are prevented by a combination of a sprinkler system, low-pressure emergency injection system, and core passive flooding system.

### **Containment System**

The land-based VBER-300 containment system includes a double protective pressure envelope formed by an inner carbon steel shell and an outer reinforced concrete containment structure. In addition, localizing reinforcement is provided to protect the pressure boundary represented by all auxiliary systems hydraulically connected to the primary loop. The containment is designed to withstand all stressors induced by all credible accident scenarios, including aircraft crashes. The inner steel containment of 30 m in diameter and 49 m high provides space for condensing the steam generated from the medium in large LOCAs. The outer concrete structure 44 m high and 36 m in diameter serves as protection against natural and man-caused impacts.

### **Plant Safety and Operational Performances**

The VBER-300 safety concept is based on the defence-in-depth principles. With the modular configuration, it has increased resistance to impact loads in case of earthquake and aircraft crash. Results of strength analysis under seismic loads of up to 8 points according to the MSK-64 scale carried out for the VBER-300 RPs confirmed that the reactor unit has a two-times safety margin (maximum seismic stress of the most loaded vessel unit is 150 MPa maximum at an allowed stress of 370 MPa). Analysis of the 20 ton aircraft crash on the reactor compartment showed that overload upon the attachment fittings of the reactor unit is less than seismic loads. It is considered that core melting accidents for the core are postulated. In the case of the severe accident, the reactor cavity is filled with water from the emergency reactor vessel cooling system ensuring reliable heat removal from the external surface of the bottom and lower portion of the vessel. Retention of satisfactory mechanical properties and load-carrying capacity of the vessel ensures retention of the melted core inside the reactor. The safety level of the power units with VBER plants correspond to requirements for Generation III+ advanced nuclear stations making it possible to place them near cities that is of extreme importance as virtually all regional power sources are used for district heating. The buffer area of the station coincides with the perimeter of the industrial site. The calculated radius of protection measures planning for population is 1 km.

## **7.1 Safety Philosophy and Implementation**

## **7.2 Transient/Accident Behaviour**

# **8. Fuel and Fuel Cycle**

## **SUMMARY FOR BOOKLET**

### **Fuel Cycle Approach**

The VBER-300 design concept allows a flexible fuel cycle for the reactor core with standard VVER

FAs. The fuel cycles are 3×2 years and 4×1.5 years. The number of FAs in the refuelling batch is either 15 or 30; maximal fuel burnup does not exceed 60 GWd/ton U for the cycle with 30 fresh FAs in the reloading batch and maximum initial uranium enrichment.

#### **8.1 Fuel Cycle Options**

#### **8.2 Resource Use Optimization**

#### **8.3 Unique Fuel/Fuel Cycle Design Features**

### **9. Safeguard & Physical Security**

#### **SUMMARY FOR BOOKLET**

##### **9.1 Safeguards**

##### **9.2 Security**

##### **9.3 Unique Safeguards and/or Security Features**

### **10. Project Delivery & Economics**

#### **SUMMARY FOR BOOKLET**

##### **10.1 Project Preparation and Negotiation**

##### **10.2 Construction and Commissioning**

##### **10.3 Operation and Maintenance**